

NEGATIVE/NEUTRAL PRESSURE

THIS SECTION IS PRESENTED FOR A BETTER UNDERSTANDING OF NEGATIVE/NEUTRAL PRESSURE FIRE RATED DOOR CONFIGURATIONS.

LAMBTON DOORS LABEL UNDER I.T.S. / WARNOCK HERSEY AS A LISTED FLUSH WOOD DOOR MANUFACTURER COMPLYING TO ALL CURRENT FIRE DOOR REQUIREMENTS MEETING ASTM E-152 FOR NEGATIVE/NEUTRAL PRESSURE AND/OR ASTM E-2074 POSITIVE PRESSURE CATEGORY 'A'.

ALL FIRE DOORS MEET THE REQUIREMENTS OF RECOGNIZED FIRE DOOR TESTS AND BEAR CERTIFYING LABELS.

TO IDENTIFY WHETHER THE DOORS YOU NEED ARE NEGATIVE/NEUTRAL PRESSURE HERE ARE THE KEY PHRASES TO LOOK FOR;

- ∅ NEUTRAL PRESSURE
- ∅ NEGATIVE PRESSURE
- ∅ UL 10-B – FIRE TEST
- ∅ UBC 7-2-1994 – UBC FIRE TEST
- ∅ UBC 432 – UBC FIRE TEST
- ∅ ASTM E-152 – TEST METHOD
- ∅ CAN S - 104
- ∅ TESTED AT ATMOSPHERIC PRESSURE